

Electrical Installation Certificate

BS 7671, new installation work (specimen)

PROPERTY	CERTIFICATE
14 High Street, Kestonbury, KT9 4LP	EIC-28-0912
INSTALLATION	DATE OF TEST
Extension circuits and consumer unit	02 May 2028
NEXT INSPECTION	SCHEME
02 May 2038	Part P registered (specimen)

Extent of work

New 10-way consumer unit with RCBO protection, six new final circuits serving the extension, kitchen ring final circuit, cooker circuit, lighting circuits and external socket.

Test results summary

Continuity of protective conductors, insulation resistance, polarity, earth fault loop impedance and RCD operating times were tested and recorded as satisfactory on the accompanying schedule of test results.

Declaration

The installation work described above has been designed, constructed, inspected and tested in accordance with BS 7671 as amended.

SIGNED

D. Vale, Qualified Supervisor

DATE

02 May 2028

Specimen only. Project Passport stores certificates supplied by others and does not verify or certify electrical work.